Energy performance certificate (EPC)		
12 Old Quay Court HOLYWOOD BT18 0HT	Energy rating	Valid until: 26 February 2034 Certificate number: 2070-8612-3140-8500-9825
Property type Total floor area	Detached bungalow 154 square metres	

Energy rating and score

This property's energy rating is F. It has the potential to be D.

See how to improve this property's energy efficiency.

Score	Energy rating	Current	Potential
92+	Α		
81-91	B		
69-80	С		
55-68	D		68 D
39-54	E		
21-38	F	23 F	
1-20	G		

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in Northern Ireland:

the average energy rating is D the average energy score is 60

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Timber frame, as built, insulated (assumed)	Good
Roof	Pitched, 250 mm loft insulation	Good
Window	Fully double glazed	Good
Main heating	Electric ceiling heating	Very poor
Main heating control	Programmer and room thermostat	Average
Hot water	Electric immersion, standard tariff, plus solar	Poor
Lighting	Low energy lighting in 35% of fixed outlets	Average
Floor	Suspended, no insulation (assumed)	N/A
Secondary heating	Room heaters, dual fuel (mineral and wood)	N/A

Low and zero carbon energy sources

Low and zero carbon energy sources release very little or no CO2. Installing these sources may help reduce energy bills as well as cutting carbon emissions. The following low or zero carbon energy sources are installed in this property:

· Solar water heating

Primary energy use

The primary energy use for this property per year is 429 kilowatt hours per square metre (kWh/m2).

How this affects your energy bills

An average household would need to spend **£6,641 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £3,931 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2024** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Impact on the environmentThis property pThis property's environmental impact rating is
F. It has the potential to be E.This property's
potential produce

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.

Carbon emissions

An average household 6 tonnes of CO2 produces

This property produces 11.5 tonnes of CO2

This property's8.4 tonnes of CO2potential production

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Changes you could make

Step	Typical installation cost	Typical yearly saving
1. Increase hot water cylinder insulation	£15 - £30	£69
2. Floor insulation (suspended floor)	£800 - £1,200	£1,028
3. High heat retention storage heaters	£2,800 - £4,200	£2,835
4. Solar photovoltaic panels	£3,500 - £5,500	£597

Help paying for energy improvements

You might be able to get a grant from the <u>Boiler Upgrade Scheme (https://www.gov.uk/apply-boiler-upgrade-scheme)</u>. This will help you buy a more efficient, low carbon heating system for this property.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Chris McLean
Telephone	07751695309
Email	chris.mclean54@yahoo.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited	
Assessor's ID	QUID209992	
Telephone	01225 667 570	
Email	info@quidos.co.uk	

About this assessment

Assessor's declaration	No related party
Date of assessment	21 February 2024
Date of certificate	27 February 2024
Type of assessment	RdSAP